

Partial Discharge Report

Report Name
Date and Time 2025-10-13 14:58:59
Site Name
Site Location
Performed By
Phone
Email



Statistics

Total Images	1
Corona	1

**Partial Discharge Info**




Max. Level 15.8 dB
Discharge Level Severe
Selected Frequency 19.9 ~ 49.9 kHz
Range
Distance 16.0 m

Image Information

Created 2025-10-12 12:48:29
File Name HM20251012124829.pd
Device Model AI76
Device Serial No. EA2404668

Discharge Type

Corona 99%
Particle 0%
Surface 0%
Floating 0%

PRPD**Signal****FFT****Text Note**