

Partial Discharge Report

Report Name
Date and Time 2025-11-25 10:32:54
Site Name
Site Location
Performed By
Phone
Email



Statistics

Total Images	1
Corona	1



Partial Discharge Info

Max. Level	24.7 dB
Discharge Level	Severe
Selected Frequency	24.4 ~ 54.4 kHz
Range	
Distance	15.0 m


Discharge Type

Corona	99%
Particle	0%
Surface	0%
Floating	0%


Image Information

Created	2025-06-02 13:22:49
File Name	HM20250602132249.pd
Device Model	AI76
Device Serial No.	EA2404668


PRPD



Signal



FFT



Text Note